



PHIFER

INCORPORATED

18 July 2014

LAFAYETTE INTERIOR FASHIONS
Sent Via E-mail: dls@lafvb.com

Re: Flame Retardance Certificate

PHIFER INCORPORATED certifies that the materials described below manufactured in Tuscaloosa, Alabama, U.S.A., and furnished by our firm are in compliance with flammability requirements* as listed:

Product Group A. SheerWeave 5000 fabrics woven from 100% FR Vinyl coated polyester. Patterns represented are limited to the following stock numbers: *P57, P58, P59, P60, P61, Q43 and Q44.*

1. Flammability per California Administrative Code, Title 19, Public Safety, Section 1237, Flame Resistance Small Scale Test. (Registration Number F-44210.)
2. National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" rating. (Tested in accordance to ASTM E84-10b.) Flame Spread Index = 15, Smoke Developed Index = 250.
3. International Building Code (IBC), Section 803.1, Class A (Tested in accordance to ASTM E84.)
4. NFPA 701, Standard Methods of Fire Tests for Flame Propagation of Textiles and Films, 2010 Edition, (Test 1, Small Scale).
5. NFPA 701, Standard Methods of Fire Tests for Flame Propagation of Textiles and Films, 2010 Edition, (Test Method # 2, Large Scale).
6. BS EN ISO 15025:2002 - Protective clothing - Protection against heat and flame - Method of test for limited flame spread (Procedure A - Surface Ignition); as cited by BS 5867-2:2008 - British Standard Specification for Fabrics for curtains, drapes and window blinds; Part 2: Type "B" Performance Requirements.
7. California Technical Bulletin #117, Section E (CS-191-53), Classification 1.

Product Group B. SheerWeave 5000 fabrics woven from Vinyl coated polyester yarns combined with up to 6%, by weight, of uncoated spun acrylic yarn. Patterns covered under this certification are limited to the following stock numbers: *Q45, Q46, Q47, Q48, Q49, Q50, Q51, Q52, Q53.*

1. National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" rating. (Tested in accordance to ASTM E84-10b.) Flame Spread Index = 20, Smoke Developed Value = 185.
2. International Building Code (IBC), Section 803.1, Class A (Tested in accordance to ASTM E84.)
3. California Technical Bulletin #117, Section E (CS-191-53), Class I.